

LiBr Absorption Refrigeration System-Based on Seebak Application

Shalini Verma¹, Satish Kumar²

Assistant Professor¹, M. Tech Scholar²

Department of Mechanical Engineering

REC, Ambedkar Nagar, UP, India¹, MNNIT Allahabad²

Corresponding Author's Email: shalinisv008@gmail.com¹

Abstract

The global increasing demand for refrigeration in field of refrigeration air-conditioning, food preservation, vaccine storages, medical services, and cooling of electronic devices, led to production of more electricity and consequently more release of CO₂ all over the world which it is contributing factor of global warming on climate change. The prices of energy have been increasing exponentially worldwide. Industrial Refrigeration is one of the most energy consuming sector. What if a refrigeration system is designed which uses no energy or minimal amount of energy? The solution lies in absorption refrigeration system. By producing an absorption refrigeration system we are not only cutting down the energy costs but also preserving our environment. This refrigeration system doesn't use any of the CFCs so our ozone layer is safe. This paper studies about LiBr/water based absorption refrigerator designed for rural application and applies solar rays based on reverse seebak effect.

Keywords: *Advanced Refrigerator, LiBR/water, Seebak Effect,*

INTRODUCTION

Refrigeration is a process in which work is done to move heat from one location to another and used to provide refrigeration for food and medicine preservation and to provide comfort cooling. The domestic

refrigerator-freezers operating on alternative refrigerants such as HFC-134a, contribute indirectly to global warming by the amount of carbon dioxide produced by the power plant in generating electricity to operate over a unit over its lifetime. This contribution is nearly 100

times greater than the direct contribution of the refrigerant alone.

Moreover, approximately 62 million new units are being manufactured worldwide every year, and hundreds of millions are currently in use. (UNEP, 1995) it is anticipated that the production of refrigerator-freezers will substantially increase in the near future as a result of the increased demand, especially in the developing countries. IPCC estimates 10% of global warming relates to man-made greenhouse gas in refrigeration and air conditioning systems.

In Europe, bans and taxes have been established. HCFCs and fluorinated refrigerant based systems are getting more difficult and expensive to use. Challenge is to make safe, reliable and suitable refrigeration systems for the markets, facilitating access to alternative technology.

The aim is to establish and replicate best practice model on the conversion of room AC; reduce rate of HCFC conversions to HFCS. HCFC emission in china account for 260 million tones of CO₂ equivalent. Solar refrigeration system is an alternative because it can convert solar energy into electricity. Therefore, thermoelectric

refrigeration is greatly needed, particularly for developing countries where long life and low maintenance are needed.

This paper studies about absorption refrigeration system based on LiBr/water for rural application and solar energy. Refrigerator which runs on electricity produced by solar energy is known as solar refrigeration. Solar-powered refrigerators may be most commonly used in the future generation developing the world to help mitigate poverty and climate change.

The solar refrigeration system is needed because of areas not connected to power grid, to minimize environmental impact and fuel cost. Solar cooling can be considered to provide refrigeration for food and medicine preservation and to provide comfort cooling. Advanced absorption cooling technology offers the possibility of chillers with greater COPs and reduces cost of the system. The invention can improve refrigerating unit, raise coefficient of performance, reduce energy cost of refrigerating unit and has notably social and economic benefit. Compared with the existing compressor refrigeration system, the system realizes simplified structure, low energy consumption and reduction of 'discharge

and environmental pollution by hazardous substance.

The aim of this paper is to improve the COP of the absorption refrigerator to make it more attractive for usage, to reduce the size of the assembly by making it more compact, to reduce the weight by using polymers, to minimize the cost as far as possible. Till date absorption refrigeration is limited for industrial purposes. I aim to make it available for mass rural use as stated above in small capacities by using solar absorption refrigerator.

This study uses refrigerant the lithium bromide as primary refrigerant and Water as secondary refrigerant and Take the mixture of lithium bromide and water in the generator.

LITERATURE REVIEW

Salah A. et.al. This paper presents a thermodynamic modeling study of the utilization of an existing high potential geothermal low-temperature heat source (114 kg/s and 73° C).

Xiaolin Wang et.al. Studied about Lithium bromide-water absorption cooling technologies is underpinned by the

continual circulation of water, which is the refrigerant, powered by the hygroscopic nature of aqueous lithium bromide solution. The present energy and global warming crises engender a renewed interest in thermally driven cooling systems, for which lithium bromide-water absorption chiller is an archetypal example forming the focus of this review (2009).

Mayank Awasthi et. al. studied to design and develop a working thermoelectric refrigerator interior cooling volume of 5L that utilizes the Peltier effect to refrigerate and maintain a selected temperature from 5 °C to 25 °C.(2012). Ian W. Eames presented an illustrated description of a proposed LiBr-H₂O vapor absorption refrigerator which uses a thermally activated solution pumping mechanism that combines controlled variations in generator vapor pressure with changes it produces in static-head pressure difference to circulate the absorbent solution between the generator and absorber vessels.

K.Balaji et.al. illustrates the thermal and fiscal advantages of using single effect lithium bromide water absorption by means of waste heat. The objective of this work is to hypothetical design of lithium bromide water absorption Refrigeration

system using waste heat from sugar industry steam turbine exhaust.

Sachin Kaushik et. al. provides an analytical study of absorption refrigeration technology. The objective of this work is to design a lithium bromide–water (LiBr-H₂O) absorption refrigerator with a nominal capacity of 5.25 kW.

The refrigeration system is based on vapour absorption cycle. In this paper the energy produces by the solar cell. The COP improve by using the seebak effect. By using LiBr/water refrigerant, this advanced system can be made eco-friendly.

PRINCIPLE

The refrigeration system is based on vapour absorption cycle. The energy produces by the solar cell. The COP improve by using the seebak effect. We use LiBr+water refrigerant, which is not harmful for the environment.

TECHNICAL DETAILS

Energy Source – In this paper energy source is taken as Solar energy- on which sun energy is converted in the electricity by using solar cell.

Seebak Effect: In this two wires of semiconductor material as silicon carbide. On one end there is hot junction and other end is cold junction, both junction produces temperature difference.

- Hot junction of seebak effect connects with the electric source of generator which minimizes the input power.
- Cold junction of seebak effect connects to the evaporator on which it increases the cooling effect.

REFRIGERANT USED

- The lithium bromide refrigerant use as primary refrigerant and
- Water used as secondary refrigerant.
- Take the mixture of lithium bromide and water in the generator.

COSTRUCTION DETAILS

- Generator-Solution of LiBr is heated to generate water vapour which is transferred to the condenser.

- Condenser- In the condenser the vapour is cooled by circulating running water.
- Expansion valve-It maintain the condenser pressure to the evaporator pressure.
- Evaporator-The water is then throttled and moved to evaporator at a low temperature and pressure where it is evaporated.
- Absorber-The water vapour is then transferred to the absorber where it is absorbed in the concentrated solution of LiBr and heat is rejected to the cooling coils.
- Pump-The water is then pumped again to the generator from where the cycle is repeated.




Fig.1: Schematic diagram of LiBr/water based adsorption refrigerator

Working-

1 to 2- Solution of LiBr is heated to generate water vapour which is transferred to the condenser. In the condenser the vapour is cooled by circulating running water.

2 to 3- The water is then throttled and moved to evaporator at a low temperature and pressure where it is evaporated.

3 to 4- The water vapour is then transferred to the absorber where it is absorbed in the concentrated solution of LiBr and heat is rejected to the cooling coils.

4 to 1- The water is then pumped again to the generator from where the cycle is repeated.

The performance of the system is governed largely by the temperature difference between the generator and the condenser and absorber units. Since the generator temperatures in solar driven systems are only moderate, it is important to keep the condenser and absorber temperatures as low as possible.

The LiBr system is preferred over ammonia systems for solar energy applications because of the lower generator temperatures required. Permissible generator temperatures for a water-cooled LiBr system range from 760 C-990 C compared to the 950 C-1200 C temperatures required for a water-cooled ammonia absorption system.

Most, if not all, of the commercially available absorption units use LiBr and water as the absorbent-refrigerant fluid pair. Because the LiBr will crystallize at

the higher absorber temperatures associated with air cooling, these units must be water cooled. A prototype ammonia-water unit, amenable to direct air cooling, has been built by Lawrence Berkeley Laboratories. Being a salt, lithium bromide does not exert any pressure and does not boil off when heated. Thus there is no need of rectifier to separate out the absorbent vapor from the refrigerant vapour

CONCLUSIONS

The coefficient of performance for this refrigeration system is low. This refrigeration system doesn't use any of the CFCs so our ozone layer is safe.

Compared with the existing compressor refrigeration system, the system realizes simplified structure, low energy consumption and reduction of 'discharge and environmental pollution by hazardous substance.

The aim of the development of the refrigeration system is to provide efficient and effective cooling in the designated locations and places. Solar power nowadays is playing a major role in meeting the energy requirements of our country. It is being developed at a very fast rate and its applications in many areas

are being explored. The refrigeration system is intended at exploring the same and provides an efficient and economical solution to the areas where there is no electricity and cooling is required.

The application of this refrigeration system is to cool appropriate amount of medicines and injections needed at the primary health care centers in villages where there is no power supply.

FUTURE SCOPE

Though this refrigeration system will work satisfactorily, still many changes and improvements can be done in this refrigeration system to make it more user friendly and sophisticated in nature. By using the peltier units, increasing the number of peltier units and by using wood as insulator material for cooling compartment.

REFERENCES

- 1) Anil Sharma, Bimal Kumar Mishra, Abhinav Dinesh, Ashok Misra (2012) "Configuration Of A 2 Kw Capacity Absorption Refrigeration System Driven By Low Grade Energy Source" International Journal Of Metallurgical & Materials Science

And Engineering (IJMMSE) Vol. 2 Issue 4 Dec - 2012 1-10, PP 1-9.

- 2) Antonio De Lucas, Marina Ind. Eng. Chem (2007). "Absorption of Water Vapor into New Working Fluids for Absorption Refrigeration Systems Chem" Res. 2007, 46, 345-350.
- 3) Astrain D. and Vian J.G. (2005), "Computational Model for Refrigerators Based on Peltier Effect Application", Applied Thermal Energy.
- 4) Christian J.L. and Jadar R. Barbosa Jr. (2011), "Thermodynamic Comparison of Peltier, Stirling and Vapor Compression Portable Coolers", Applied Energy.
- 5) Dillip Kumar Mohanty, Abhijit Padhiary (2015) "Thermodynamic Performance Analysis of a Solar Vapour Absorption Refrigeration System" International Journal of Enhanced Research in Science Technology & Engineering, ISSN: 2319-7463 Vol. 4 Issue 4, April-2015, pp: (45-54).

- 6) G. Ali Mansoori And Vinod Patel (1979) "Thermodynamic Basis For The Choice Of Working Fluids For Solar Absorption Cooling Systems" Solar Energy, Volume 22, Issue 6, 1979, PP 483-491.
- 7) Horway J. B.(1961) "The Peltier Effect and Thermoelectric Transients", University of Louisvill.
- 8) Jaspalsinh B.(2012), "A Design Method of Thermo Electric Cooler", IJME, Vol.5, No. 1, PP. 37-40.
- 9) K.Balaji, R.Senthil Kumar (2012) "Study of Vapour Absorption System Using Waste Heat in Sugar Industry" IOSR Journal of Engineering (IOSRJEN) ISSN: 2250-3021 Volume 2, Issue 8 (August 2012), PP 34-39.
- 10) K.R. Ullah, R. Saidur, H.W. Ping, R.K. Akikur, N.H. Shuvo (2013) 'A review of solar thermal refrigeration and cooling methods, Renewable and Sustainable Energy Reviews 24 (2013) 490–513.
- 11) Mayank Awasthi, K.V. Mali(2012), "Design and Development of Thermoelectric Refrigerator "International Journal of Mechanical Engineering and Robotics, Vol.1, No.3, Oct. 2012.
- 12) Mehrdad Khamooshi, Kiyan Parham, and Ugur Atikol (2013) 'Overview of Ionic Liquids Used as Working Fluids in Absorption Cycles',Advances in Mechanical Engineering Volume, 72 (2013) 1-7.
- 13) Minh, Nguyen Q.; Hewitt, Neil James; And Eames, Philip Charles (2006) "Improved Vapour Absorption Refrigeration Cycles: Literature Review and Their Application To Heat Pumps" International Refrigeration And Air Conditioning Conference, 2006 Paper 795, Pp1-8.
- 14) M. Izquierdo, M. Venegas, P. Rodriguez (2016) "A. Lecuona, Crystallization as a limit to develop solar air-cooled LiBr–H₂O absorption systems using low-grade heat" Solar Energy Materials and Solar Cells 81 (2004) 205–2016.

- 15) Mr. S. S. Mali , Prof.M.M.Wagh,
Prof. N. N. Shinde (2013) “Review
Of Design Of Single Effect Solar
Powered Vapour Absorption Air
Conditioning System”
International Journal Of Advance
Research In Science And
Engineering, Vol. No.2, Issue
No.7, July, 2013, PP 44-52
- 16) Pongsid Sriksirin, Satha
Aphornratana, Supachart
Chungpaibulpatana (2001) “A
Review Of Absorption
Refrigeration Technologies”
Renewable And Sustainable
Energy Reviews 5, 2001 Pp-343–
372.
- 17) Rabah GOMRI Int. J(2010). ‘Solar
Energy to Drive Half-Effect
Absorption Cooling System’
Thermal & Environmental
Engineering Volume 1, No. 1
(2010) PP.1-8
- 18) Sachin Kaushik , Dr. S. Singh
(2014) “Thermodynamic Analysis
of Vapor Absorption Refrigeration
System and Calculation of COP”
International Journal For Research
in Applied Science and
Engineering Technology
(IJRASET) ISSN: 2321-9653 Vol.
2 Issue II, February 2014.
- 19) Salah A. A.Masheiti ‘Modelling of
lithium-bromide (LiBr) chillers
and organic Rankine cycle (ORC)
powered by low temperature
geothermal heat source’.
- 20) Shubham Srivastava, Ravi Kumar
Sen, Arpit Thakur, Manish Kumar
Tated “Review Paper on Analysis
of Vapour Absorption
Refrigeration System”
International Journal of Research
in Engineering and Technology
eISSN: 2319-1163 | pISSN: 2321-
7308.
- 21) Sierra FZ, Best R, Holland
FA(1993) “Experiments on an
absorption refrigeration system
powered by a solar pond Heat
Recovery System” CHP
1993;13:401–8.
- 22) Soteris Kalogirou, George
Florides, Savvas Tassou, Louis
Wrobel (2001) ‘Design And
Construction Of A Lithium
Bromide Water Absorption
Refrigerator’ Clima 2000/Napoli

2001 WorldCongress – Napoli (I),
15-18 September 2001.

23) Uppal AH, Norton B, Probert
SD(1986). “A low-cost
solarenergy stimulated absorption
refrigerator for vaccine storage.
Applied Energy” 1986;25:167–74.

24) Xiaolin Wang and Hui T.
Chua(2009) ‘Absorption Cooling:
A Review of Lithium Bromide-
Water Chiller Technologies’
Received: May 20, 2009;
Accepted: July 7, 2009 Revised:
July 17, 2009 Recent Patents on
Mechanical Engineering 2009, 2,
193-213.