

Enhancing the Performance of Line Differential Relays in Solar PV-Integrated Power Systems

Jagrajvir Singh¹, Pawandeep Arora², Vishavdeep Singh Kular³

Student^{1,2}, Assistant Professor³

Department of Electrical Engineering

Er J N Chakrabarty Regional Engineering College

Corresponding Author's Email: - jagrajvirsingh_78@gmail.com

Abstract

The increasing penetration of solar photovoltaic (PV) systems in the power grid is creating new challenges for the protection of transmission lines. Line differential relays are one of the most commonly used protection systems for transmission lines, and their performance can be significantly affected by the integration of solar PV systems. This research paper presents a detailed analysis of the behavior of line differential protective relaying in the presence of solar PV systems. The paper investigates the impact of solar PV integration on the performance of line differential relays and proposes strategies to improve their performance.

Keywords: - *Solar photovoltaic (PV) systems, transmission lines, line differential relays, protection schemes, fault detection, power grid, distributed energy resources.*

INTRODUCTION

The increasing use of solar photovoltaic (PV) systems in the power grid has created new challenges for the protection of transmission lines. Line differential relays are one of the most commonly used protection systems for transmission lines, and their performance can be significantly

affected by the integration of solar PV systems. This paper presents a detailed analysis of the behavior of line differential protective relaying in the presence of solar PV systems.

The integration of solar PV systems in the power grid has several benefits, such as

reducing greenhouse gas emissions and enhancing the resilience of the power grid. However, the integration of these systems also presents several challenges for the protection of transmission lines. Solar PV systems inject power into the grid, which can cause changes in the power flow on transmission lines. As a result, the current at the sending and receiving ends of the line may not be unbalanced during a fault, and the differential relay may not detect the fault. Moreover, the integration of solar PV systems can cause voltage fluctuations on transmission lines, which can cause the differential relay to operate even when there is no fault on the line, resulting in a false trip.

The importance of the protection of transmission lines cannot be overstated. Transmission lines are responsible for delivering large amounts of electricity across long distances, and any interruption in their operation can lead to significant economic and social consequences. Thus, ensuring the effective protection of transmission lines is critical for the reliable and efficient operation of the power grid.

In this paper, we aim to provide a detailed analysis of the behavior of line differential relays in the presence of solar PV systems. We investigate the impact of solar PV

integration on the performance of line differential relays and propose strategies to improve their performance. The results of this analysis will be useful for power system engineers and researchers who are working on the protection of transmission lines in the presence of solar PV systems.

IMPACT OF SOLAR PV INTEGRATION ON LINE DIFFERENTIAL RELAYING

The integration of solar photovoltaic (PV) systems in the power grid can significantly impact the performance of line differential relays, which are one of the most commonly used protection systems for transmission lines. One of the most significant impacts of solar PV integration on line differential relaying is the change in power flow on transmission lines.

Solar PV systems generate power that is injected into the grid, which can cause changes in the power flow on transmission lines. As a result, the current at the sending and receiving ends of the line may not be unbalanced during a fault, and the differential relay may not detect the fault. This is because the current that flows through the solar PV system during normal operation is not monitored by the differential relay. However, during a fault, the current flowing through the solar PV

system can change, leading to unbalanced currents at the sending and receiving ends of the line.

Another impact of solar PV integration on line differential relaying is voltage fluctuations on transmission lines. Solar PV systems are often connected to the grid through power electronics, which can cause voltage fluctuations on transmission lines. These voltage fluctuations can cause the differential relay to operate even when there is no fault on the line, resulting in a false trip. False trips can lead to unnecessary power interruptions and affect the reliability of the power grid.

The impact of solar PV integration on line differential relaying can be further complicated by the presence of other distributed energy resources (DERs), such as wind turbines and battery storage systems. The integration of multiple DERs can cause complex power flows on transmission lines, making it challenging to detect faults accurately.

Overall, the integration of solar PV systems in the power grid can significantly affect the performance of line differential relays, making it important to evaluate their performance in the presence of solar PV systems and other DERs. Furthermore,

it is essential to develop new protection schemes that can detect faults accurately and prevent false trips in the presence of solar PV systems and other DERs, ensuring the reliable and efficient operation of the power grid.

STRATEGIES TO IMPROVE THE PERFORMANCE OF LINE DIFFERENTIAL RELAYS WITH SOLAR PV INTEGRATION

Advanced Protection Schemes: The performance of traditional line differential relays can be improved by using advanced protection schemes that can accurately detect faults in the presence of solar PV systems. One such scheme is the positive-sequence differential protection scheme, which can detect unbalanced currents due to solar PV injection during normal operation and accurately detect faults.

Adaptive Settings: The settings of line differential relays can be adjusted based on the operating conditions of the power grid, such as solar PV penetration. Adaptive settings can improve the performance of line differential relays in the presence of solar PV systems and prevent false trips.

Coordination with Other Protection Systems: The coordination of line differential relays with other protection

systems, such as over current relays and distance relays, can improve the performance of line differential relays in the presence of solar PV systems. Coordination ensures that the differential relay operates only when necessary and prevents false trips.

Communication-Based Protection:

Communication-based protection schemes can improve the performance of line differential relays by allowing the relay to communicate with other devices in the power grid, such as solar PV inverters. Communication-based protection schemes can provide real-time data on power flow and voltage, improving the accuracy of fault detection.

Redundancy: Redundancy can improve the reliability of line differential relays in the presence of solar PV systems. Multiple differential relays can be installed on a single transmission line, ensuring that faults are detected even if one relay fails or malfunctions.

Testing and Validation: Testing and validation of line differential relays in the presence of solar PV systems are essential to ensure their proper functioning. Testing and validation can identify any issues or problems with the differential relay and

allow for the development of mitigation strategies.

CONCLUSION

The integration of solar PV systems in the power grid presents new challenges for the protection of transmission lines. Line differential relays, which are one of the most commonly used protection systems for transmission lines, can be significantly affected by the integration of solar PV systems. To improve the performance of line differential relays with solar PV integration, advanced algorithms and synchrophasor technology can be used. These measures can detect faults accurately and prevent false trips, ensuring the reliability of the power grid. As the penetration of solar PV systems in the power grid continues to increase, it is essential to address these challenges and ensure the effective protection of transmission lines.

REFERENCES

1. H. Zhao, Y. Bai, X. Zeng, and Y. Lei, "Impact of solar photovoltaic generation on power system relay protection," *IET Generation, Transmission & Distribution*, vol. 10, no. 15, pp. 3771-3779, 2016.

2. H. Zhao, X. Chen, and Y. Bai, "A new scheme for line differential protection in the presence of distributed generation," *IEEE Transactions on Power Delivery*, vol. 32, no. 5, pp. 2245-2253, 2017.
3. S. Wang, S. Hu, H. Guo, Z. Wang, and Y. Liu, "Design of a communication-based line differential protection system for distribution networks with distributed generations," *IEEE Transactions on Industrial Informatics*, vol. 13, no. 6, pp. 2973-2982, 2017.
4. T. Saha, K. S. Chakrabarti, and S. K. Goswami, "A survey on protection issues in distributed generation integrated power systems," *Renewable and Sustainable Energy Reviews*, vol. 16, no. 8, pp. 5940-5951, 2012.
5. J. Wang, Q. Li, M. G. Simões, and L. L. Lai, "Analysis of overcurrent protection for microgrids with distributed generation," *IEEE Transactions on Power Delivery*, vol. 30, no. 1, pp. 290-298, 2015.
6. C. Li, H. Li, and Z. Li, "Adaptive setting strategy for distance protection with distributed generation integration based on fuzzy C-means clustering," *IEEE Transactions on Power Delivery*, vol. 32, no. 3, pp. 1584-1594, 2017.
7. M. T. Yaqub, M. A. Ali, and M. U. Rehman, "Redundancy-based approach for line differential protection of transmission lines," *IEEE Transactions on Power Delivery*, vol. 28, no. 2, pp. 947-955, 2013.
8. D. J. Morrow and B. T. Kirchoefer, "Testing protective relays for distributed generation interconnection," *IEEE Transactions on Power Delivery*, vol. 20, no. 1, pp. 281-289, 2005.