

Next-Gen Energy Solutions: High-Efficiency Solar ICs for Biomedical Implant Technology

Gayatri Pawar¹, Anand Kashyap²

Student¹, Professor²

Department of CSE

Sinhgad Academy of Engineering, Pune, India

Corresponding Author's Email: pawar00@gmail.com¹

Abstract

This article introduces a single-chip solar energy harvesting integrated circuit (IC) with exceptional efficiency, specifically designed for biomedical implant applications and utilizing an on-chip solar cell. The incorporation of an on-chip charge pump, coupled with parallel-connected photodiodes, results in a remarkable 3.5-fold improvement in efficiency compared to the conventional stacked photodiode approach, effectively enhancing the harvested voltage. To further enhance area efficiency and accelerate startup speed by 77%, a photodiode-assisted dual startup circuit (PDSC) is employed. The high-efficiency system is implemented using 0.18- μm CMOS technology, occupying a compact active area of approximately 1.54 mm². The utilization of an on-chip charge pump achieves a maximum efficiency of 67% with an incident power of 1.22 mW/cm².

Keywords: *Single chip solar energy harvesting, on chip charge pump, Auxiliary charge pump, Photodiode-assisted dual startup circuit.*

INTRODUCTION

In e-healthcare system patient can monitor their own health status at home which include information about ECG, breathing glucose level and heart rate etc. Recently solar energy

harvesting is used in biomedical implant applications includes intraocular pressure monitoring [1] and subdermal implant applications [2]. In many implantable device wires are used to provide power from and to the device, but due to that it has limited distance, provide power to the chip [3]. In many applications today batteries are used but batteries can be very hazardous if they leak within the body. Clearly, batteries have limited lifetimes and after some time will be fully discharged [4]. So we can use solar energy harvesting IC in biomedical applications but we need such IC which provides highest efficiency. By integrating CMOS circuitry and solar energy harvesting on same chip we can reduce the total area of chip. Photodiode provide voltage in between 0.3 to 0.4V. This is too small voltage we need a system which provide high output power. So for that various solutions are available like silicon on insulator with serial connected photodiode with separate substrate, due to separate substrate used it increased the cost of chip [5]. In [6] and [7] different approaches to serial connected photodiodes are used but due to single substrate limitation it is not used also it reduces the overall efficiency of chip. DC-DC converter is used to boost the voltage also inductor based boost converter is available but it requires large off chip components [8].

To solve this problem on chip charge with along with photodiode is used to increase the overall efficiency and to boost the voltage level [9]. Also low input solar energy harvesting is available which provides 0.15 V with dynamic biasing, it requires 6 off chip components which increase the complexity of circuit [10]. Complete die -stacked platform is used to boost the voltage level [11].

BLOCK DIAGRAM

In figure 1 shows the system architecture of solar energy harvesting IC used in subdermal implant application. It is responsible for harvesting the incoming solar energy, process the incoming solar energy and transmit wirelessly to the dedicated medical server for further analysis process. Solar energy harvest the incoming solar energy from on chip solar cell and provide power to the voltage reference, clock phase generator, auxiliary charge pump and main charge pump etc. In order to reduce the noise coupling on chip solar cell divided into three building blocks like DM, DP and DR.

Voltage reference provides the reference voltage to the clock phase generator along with PDSC. PDSC is the photodiode-assisted dual startup circuit used to improve the startup failure problem from voltage reference block. Clock phase generator provides two different non overlapping clock pluses Φ_1 and Φ_2 from five stage ring oscillator. Level converter generates four high swing clock pluses Φ_{x1}/Φ_{x2} and Φ_{o1}/Φ_{o2} to main charge pump.




Figure 1 Solar

harvesting IC used in subdermal implant application

energy




Figure 2 Measured efficiency under different incident power levels

	TED'12 [6]	TVLSI'11 [13]	TOBCS'17 [12]
Process (μm)	0.35	0.35	0.18
Light Source	White LED	Green Laser (532 nm)	Halogen Lamp
Incident Light Intensity	31 klx	34.2 μW	1.13 m/W mm^2
Area	0.69* mm^2 1.38^ mm^2	338 μm^2	1.54 mm^2
V_{oc} (V)	0.52*	0.533	0.53
I_{sc} (μA)	17.5*	680	750
P_{out} (μW)	7.14*	225	322

Table 1 Comparison with existing single-chip solar energy harvesting IC

Eff. (%)	9.5* [‡]	24	21.9*
Voltage Boosting	Stacked	-	On-Chip Charge Pump
V _{out, boosted} (V)	0.97 ^{^†}	-	1.08 [‡]
E f f _{boosted} (%)	3.5 [^]	-	12.1 [‡]

RESULTS AND DISCUSSION




Figure 3 Power of the proposed photodiode with charge pump and the stacked photodiode

The single-chip solar energy harvesting system is designed and fabricated in a standard 0.18-μm CMOS process. Halogen light source is used here. If incident power is less then we get maximum efficiency as incident power increases then efficiency of chip reduces [12]. Table 1 gives information about the performance comparison with existing single-chip solar energy harvesting IC. Conventionally, bootstrapping and ZVT switches are used for solar energy harvesting applications due to the low input voltage. This will increase the reversion loss due to the increased leakage and sacrificing the overall efficiency. The use of non-uniform gate drive voltages can also increase the conduction loss. To reduce these losses on chip charge pump along with ZVT switches are used. Figure 2 give information about how input power affect on the overall chip efficiency. We can connect photodiode either parallel or stacked. If we connect photodiode in parallel along on chip charge pump we get maximum power, if we connect photodiode serially we get low output power shown in figure 3.

CONCLUSION

In this paper single-chip solar energy harvesting IC using on-chip photodiodes is explained. With the help of on chip charge pump and parallel connected photodiode we get $3.5 \times$ improvements in energy harvesting efficiency. When we compared with stacked photodiode. Also due to use of PDSC circuit 77% efficiency improvement achieved. Use of on- chip charge pump along with zero threshold switches we can reduces the both inversion and conduction loss and achieve highest efficiency at the output.

REFERENCES

1. G. Chen, H. Ghaed, R. Haque, M. Wieckowski, Y. Kim, G. Kim, D. Fick, D. Kim, M. Seok, K. Wise, D. Blaauw, and D. Sylvester, "A cubicmillimeter energy-autonomous wireless intraocular pressure monitor, in Proceeding of the Solid-State Circuits Conference Digest of Technical Papers, San Francisco, 2011, pp. 310-312.
2. S. Ayazian, V. Akhavan, E. Soenen, and A. Hassibi, "A photovoltaic driven and energy-autonomous CMOS implantable sensor," IEEE Transaction on Biomedical Circuits and Systems, vol. 6, no. 4, pp. 336-343, Aug. 2012.
3. M. Monge, M. Raj, M. H. Nazari, H. C. Chang, Y. Zhao, J. D. Weiland, M. S. Humayun, Y. C. Tai, and A. Emami, "A fully intraocular high-density self-calibrating epiretinal prosthesis," IEEE Transaction on Biomedical Circuits and Systems., vol. 7, no. 6, pp. 747-760, Dec. 2013.
4. S. Ayazian, V. A. Akhavan, E. Soenen, and A. Hassibi, "A photovoltaic driven and energy-autonomous CMOS implantable sensor," IEEE Transaction on Biomedical Circuits and Systems, vol. 6, no. 4, pp. 336-343, Aug. 2012.
5. M. A. Marwick and A. G. Andreou, "Photo-battery fabricated in silicon on sapphire CMOS," IEEE Electronics Device Letters, vol. 44, no. 12, pp. 766-767, Jun. 2010.

6. F. Horiguchi, "Integration of series-connected on-chip solar battery in a triple-well CMOS LSI," IEEE Transaction on Electron Devices, vol. 59, no. 6, pp. 1580-1584, Jun. 2012.
7. M. K. Law and A. Bermak, "High-voltage generation with stacked photodiodes in standard CMOS process," IEEE Electron Device Letters, vol. 31, no. 12, pp. 1425-1427, Dec. 2010.
8. S. Ghosh, H. T. Wang, and W. D. Leon-Salas, "A circuit for energy harvesting using on-chip solar cells," IEEE Transaction on Power Electron., vol. 29, no. 9, pp. 4658-4671, Sep. 2014.
9. Y. Shih and B. P. Otis, "An inductor-less DC-DC converter for energy harvesting with a 1.2- μ W bandgap-referenced output controller," IEEE Transaction on Circuits and Systems- II, Express Briefs, vol. 58, no. 12, pp. 832-836, Dec. 2011.
10. J. Kim, P. K. T. Mok, and C. Kim, "A 0.15V input energy harvesting charge pump with dynamic body biasing and adaptive dead-time for efficiency improvement," IEEE Journal on Solid State Circuits, pp. 414-425, Feb. 2015.
11. Y. Lee, S. Bang, I. Lee, Y. Kim, G. Kim, M. H. Ghaed, P. Pannuto, P. Dutta, D. Sylvester, and D. Blaauw, "A modular 1 mm³ die-stacked sensing platform with low power I2C inter-die communication and multimodal energy harvesting," IEEE Journal on Solid-State Circuits, vol. 48, no. 1, pp. 229-243, Jan. 2013.
12. Z. Chen, M. Law and P. Mak, "A Single-Chip Solar Energy Harvesting IC Using Integrated Photodiodes for Biomedical Implant Applications," IEEE Transactions On Biomedical Circuits And Systems, vol. 11, no. 1, pp. 44-53, Feb. 2017.
13. N. Guilar, A. Chen, T. Kleeburg, and R. Amirtharajah, "Integrated Solar Energy Harvesting and Storage," IEEE Transaction on Very Large Scale Integration (VLSI) Systems, vol. 17, no. 5, pp. 627-632, Feb. 2011.