MANTECH Publications

Recent Trends in Electrical Machines and Drives

Volume 5, Issue 2, May- August 2020

Smart Sensing and Control of Converter-Induced Harmonics in Renewable Systems

Rajender Baitha

Associate Professor

Department of Electrical Machines

Government Arts College, Perambalur, India

Email: - *Rajesnder_08baa@gmail.com*

ABSTRACT

The integration of renewable energy sources (RES) into modern power systems has become crucial for achieving sustainable and low-carbon energy solutions. Power electronic converters, such as inverters and DC-DC converters, act as the interface between RES and the grid. However, these converters are significant sources of harmonic distortion, adversely affecting power quality, system reliability, and equipment lifespan. This paper reviews recent advancements in ***smart sensing and control strategies*** *for mitigating converter-induced harmonics in renewable energy systems. It explores harmonic generation mechanisms, monitoring techniques, and advanced control methodologies, including active filtering, predictive control, and artificial intelligence-based strategies. Practical implementations, challenges, and future directions are also discussed. The review emphasizes the importance of integrating* ***smart sensing, real-time monitoring, and adaptive control*** *to maintain grid stability and ensure efficient renewable energy utilization.*

KEYWORDS: *Renewable energy systems, power quality, harmonics, smart sensing, power electronics, predictive control, active filters, adaptive control, grid integration, inverters.*

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

INTRODUCTION

The increasing deployment of renewable energy sources such as solar photovoltaic (PV) arrays, wind turbines, and energy storage systems has necessitated widespread use of power electronic converters. These converters efficiently regulate voltage and current and facilitate grid integration, but they introduce **harmonics** into the power network. Harmonics are voltage or current components at multiples of the fundamental frequency that distort the waveform, leading to increased losses, overheating of electrical machines, interference with communication systems, and maloperation of protective devices.

Modern grids demand **high-quality electrical power**, and excessive harmonic distortion can jeopardize both grid reliability and equipment safety. Traditional passive filters have limitations in adaptability and efficiency, particularly in systems with fluctuating renewable outputs. Hence, **smart sensing and adaptive control** of converter-induced harmonics have emerged as critical areas of research. These approaches combine real-time monitoring, advanced signal processing, and intelligent control techniques to dynamically detect and mitigate harmonic disturbances.

This paper provides a comprehensive review of mechanisms causing harmonics in renewable systems, techniques for harmonic sensing, and state-of-the-art control strategies for mitigation. It also highlights research gaps and future directions for intelligent harmonic management.

HARMONICS IN RENEWABLE ENERGY SYSTEMS

Harmonics are unwanted frequency components present in electrical signals at integer multiples of the fundamental frequency (usually 50 or 60 Hz). In renewable energy systems, harmonics arise primarily due to the **nonlinear switching nature of power electronic converters**. Unlike traditional rotating machines, converters synthesize AC waveforms from DC sources using high-frequency switching, which introduces **voltage and current distortions**. Persistent harmonic presence can degrade system performance, reduce reliability, and increase operational costs. Understanding their sources, effects, and regulatory standards is crucial for designing reliable renewable energy systems.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

1. Sources of Harmonics

Power electronic converters are indispensable for interfacing renewable energy sources (RES) with the grid or loads. However, their switching action creates **non-sinusoidal voltage and current waveforms**, which manifest as harmonics. The primary sources in renewable systems are:

1. **Grid-tied inverters:**
   - Pulse-width modulation (PWM) inverters are widely used for solar PV and battery systems.
   - High-frequency switching (typically 2–20 kHz) generates **high-order harmonics**, while the non-ideal switching patterns introduce **low-order harmonics** (3rd, 5th, 7th).
   - Example: A 5 kW solar inverter can inject harmonics causing **3–8% THD** into the local distribution network if unmitigated.

2. **DC-DC Converters:**
   - Buck, boost, and multi-level DC-DC converters regulate voltage for PV arrays, wind turbine rectifiers, and storage units.
   - They produce **current ripples** on both the input and output sides due to switching, which propagate to the AC grid through inverters.
   - Multi-level converters reduce harmonic amplitude but cannot eliminate higher-order components entirely.
3. **Wind Turbine Converters:**
   - Modern wind turbines often use **Doubly-Fed Induction Generators (DFIGs)** with rotor-side converters.
   - Rotor-side PWM control introduces **low-order harmonics** (2nd, 3rd, 5th), while grid-side converters generate high-frequency harmonics due to fast switching.
   - Harmonics can interact with the mechanical system, producing torque pulsations that further affect generator life.
4. **Energy Storage Systems (ESS):**
   - Battery energy storage systems (BESS) and supercapacitor-based systems use bidirectional converters for charging and discharging.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

- These converters introduce **high-frequency harmonics**, especially during rapid charge/discharge cycles.
- Harmonic injection from multiple ESS units can cumulatively increase the overall system THD, particularly in microgrids.

5. **Other Nonlinear Loads in Renewable Microgrids:**
   - Electric vehicle chargers, smart loads, and embedded power electronics in hybrid systems also contribute harmonics.
   - These components, when connected alongside RES converters, can **exacerbate harmonic interactions**, creating complex waveforms in the grid.

2. Harmonic Effects

Harmonics, if not properly controlled, adversely impact both the **power system and connected devices**. The main effects include:

1. **Thermal Stress:**
   - Harmonic currents increase I^2R losses in transformers, cables, and motors.
   - Example: 5th harmonic current can cause a **10–15% temperature rise** in transformer windings.
   - Prolonged heating accelerates insulation degradation, reducing equipment lifespan.

2. **Power Losses and Efficiency Reduction:**
   - Nonlinear currents lead to additional losses in converters and distribution lines.
   - In inverters, harmonics increase switching and conduction losses, lowering overall **conversion efficiency by 2–5%** in small-scale systems.

3. **Voltage Distortion and Maloperation of Sensitive Loads:**
   - Harmonics distort the voltage waveform, causing erratic operation of sensitive electronics, such as variable-frequency drives (VFDs), PLCs, and communication devices.
   - Resonance between the source impedance and load capacitance can amplify certain harmonic orders, exacerbating the problem.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

4. **Resonance and Stability Issues:**
   - Harmonics can excite resonance in passive network components like L-C circuits or filters.
   - This leads to **overvoltages, oscillations, and potential damage** to system components.
   - In distributed renewable systems, harmonic resonance can destabilize the microgrid, particularly during low load or islanded operation.

5. **Interference with Grid Protection and Metering:**
   - Harmonics can cause **nuisance tripping** of protective relays, misoperation of smart meters, and errors in energy accounting.

HARMONIC STANDARDS

To ensure power quality and grid reliability, international standards define permissible harmonic limits:

1. **IEEE 519-2014:**
   - Provides **guidelines for voltage and current distortion** in industrial and utility systems.
   - Specifies **Total Harmonic Distortion (THD)** limits:
   - Voltage THD: ≤5% at the point of common coupling (PCC).
   - Current THD: Depends on system voltage and short-circuit ratio (typically ≤8–20%).

2. **IEC 61000 Series:**
   - Defines immunity and emission limits for harmonics in power systems and electronic equipment.
   - Ensures that devices operate reliably without introducing excessive distortion.

3. **Local Grid Codes:**
   - Regional utility regulations may impose stricter limits depending on system voltage, type of renewable source, and network configuration.

Compliance with these standards is critical to:

- Avoid penalties from utilities.
- Maintain equipment safety and performance.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

- Ensure stable integration of renewable energy into the grid.

SMART SENSING TECHNIQUES FOR HARMONICS

Effective mitigation of converter-induced harmonics in renewable energy systems begins with **accurate sensing and real-time monitoring**. Harmonics in RES are often dynamic, as renewable generation is intermittent and load conditions vary. Traditional harmonic detection methods, such as standard Fourier analysis, often fail to capture **rapid fluctuations or high-frequency components** accurately. Modern smart sensing techniques integrate **advanced signal processing, artificial intelligence (AI), and networked sensor architectures** to provide adaptive, precise, and real-time harmonic measurements. These techniques form the foundation for intelligent harmonic control strategies.

1. Measurement Techniques

Modern renewable systems use various hardware-based sensing solutions for harmonic detection. Key techniques include:

1. **Digital Signal Processing (DSP)-based Sensors**
   - DSP units are embedded in measurement devices to capture instantaneous voltage and current waveforms at high sampling rates (10–50 kHz).
   - Harmonic components are extracted using algorithms like **Fast Fourier Transform (FFT)** or **Discrete Wavelet Transform (DWT)**.
   - **Advantages:** Real-time monitoring, high accuracy, capability to track multiple harmonic orders simultaneously.
   - **Example:** A 10 kW grid-tied inverter can be equipped with a DSP sensor that tracks 3rd to 13th harmonic currents, allowing immediate corrective actions through active filters.
2. **Phasor Measurement Units (PMUs)**
   - PMUs measure **magnitude and phase of voltage and current phasors** at high precision, synchronized using GPS signals.
   - They are particularly useful for **wide-area harmonic monitoring** in distribution networks with multiple renewable sources.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

- **Advantages:** Enables grid operators to observe harmonic propagation across the network and detect resonance issues.
- **Example:** PMUs installed in a wind farm can identify low-frequency harmonics caused by DFIG converters and send real-time data to a centralized control center.

3. **IoT-enabled Smart Sensors**
   - Sensors equipped with IoT connectivity provide **distributed measurement capabilities**, sending real-time data to cloud-based monitoring platforms.
   - They allow **remote harmonic detection**, logging, and predictive analysis.
   - **Advantages:** Low-cost deployment, scalability, and integration with AI-based controllers for adaptive harmonic mitigation.
   - **Example:** A microgrid with solar, wind, and battery storage can deploy IoT sensors at key points (converter outputs, load centers, and PCC) to continuously monitor THD and identify local harmonic sources.

2. Signal Processing Approaches

Raw sensor data require advanced processing to **extract harmonic information** accurately, especially under dynamic conditions typical of renewable energy systems.

1. **Wavelet Transform (WT)**
   - Unlike FFT, WT provides **time-frequency representation**, making it suitable for **non-stationary signals** produced by fluctuating RES outputs.
   - Captures both **high-frequency transient harmonics** and low-frequency steady-state components.
   - **Application:** Detecting sudden voltage spikes or harmonics due to cloud shading on PV panels or gusty wind conditions.

2. **Kalman Filtering**
   - A recursive algorithm that estimates the **true harmonic components** from noisy measurements.
   - Provides smooth tracking of THD and individual harmonic amplitudes in real-time.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

- **Advantages:** Effective for systems with measurement noise or rapidly changing harmonics.
- **Example:** In a hybrid PV-wind microgrid, Kalman filtering can track the 5th and 7th harmonics in the inverter output and inform adaptive controllers to inject compensating currents.

3. **Artificial Intelligence (AI) Approaches**
   - AI techniques, such as **neural networks, fuzzy logic, support vector machines (SVMs), and reinforcement learning**, can **predict and classify harmonic patterns**.
   - Capable of proactive mitigation by anticipating harmonic generation before it affects the grid.
   - **Example:** A neural network trained on historical inverter output can predict harmonic spikes during rapid solar irradiance changes, allowing the APF to act preemptively.
   - **Benefits:** Self-learning, adaptive, and scalable; suitable for complex systems with multiple RES sources.

3. Sensor Placement Strategies

The **location of sensors** critically affects the accuracy and effectiveness of harmonic monitoring. Optimized placement ensures comprehensive coverage while minimizing costs.

1. **Converter Terminals**
   - Placing sensors at inverter or DC-DC converter terminals captures harmonics **directly at the source**, enabling immediate corrective actions.
   - Ideal for high-frequency harmonic detection.
2. **Critical Loads**
   - Sensors installed at sensitive equipment (VFDs, data centers, or communication devices) help detect harmonics that could affect load performance.
   - Useful for localized mitigation.
3. **Point of Common Coupling (PCC) or Grid Interface**

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

- Measuring harmonics at PCC provides a **system-wide view** of voltage distortion and aggregate harmonic contribution from multiple sources.
- Facilitates compliance with grid standards like IEEE 519-2014.

4. **Distributed Sensor Networks**
   - Using multiple IoT-enabled sensors across the microgrid ensures **redundancy, higher reliability, and detection of harmonic propagation paths**.
   - Enables **coordinated mitigation** strategies where multiple converters interact.

CONTROL STRATEGIES FOR HARMONIC MITIGATION

Controlling converter-induced harmonics involves **passive, active, and hybrid methods**, with smart approaches enhancing adaptability.

1. Passive Filtering

Passive filters use **LC or LCL networks** to block specific harmonic frequencies. While inexpensive, they are:

- Limited in adaptability to varying loads and RES output.
- Susceptible to resonance and performance degradation at higher harmonics.

2. Active Harmonic Compensation

Active power filters (APFs) inject compensating currents to cancel harmonics. Key types include:

- **Shunt APFs:** Inject current to neutralize harmonic currents in the line.
- **Series APFs:** Inject voltage to mitigate harmonic voltage distortion.
- **Hybrid Filters:** Combine passive and active elements to optimize cost and performance.

3. Intelligent Control Techniques

Smart control strategies utilize real-time harmonic sensing and advanced algorithms to dynamically reduce distortion.

1. Model Predictive Control (MPC)

- Uses a dynamic model of the converter and grid to predict future harmonics.
- Computes optimal switching commands to minimize THD.
- Benefits: High precision and adaptability to fluctuating RES output.

2. Fuzzy Logic and AI-based Controllers

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

- Fuzzy logic controllers adjust switching patterns based on real-time harmonic levels.
- Neural networks predict harmonic trends and optimize compensation proactively.
- Reinforcement learning methods adaptively tune filters for best performance over time.

3. Multi-Level Converter Control

- Multi-level inverters reduce harmonic content inherently by synthesizing stepped voltage waveforms.
- Combined with AI-based switching, these converters achieve minimal THD without bulky filters.

INTEGRATION OF SMART SENSING WITH CONTROL

The synergy between smart sensing and intelligent control is crucial:

- Real-time harmonic data feeds into predictive algorithms.
- Adaptive controllers modify PWM or switching sequences to minimize distortion.
- IoT-enabled monitoring allows centralized or distributed harmonic management.




Figure 1: Smart Sensing and Control Framework for Harmonic Mitigation

Table 1 summarizes different control strategies and their characteristics.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

Strategy	Technique	Advantages	Limitations
Passive Filtering	LC, LCL filters	Simple, low-cost	Fixed tuning, resonance issues
Active Filtering	Shunt, Series, Hybrid	Adaptive, precise compensation	Higher cost, control complexity
Model Predictive Control	Predictive switching	High THD reduction, adaptable	Computationally intensive
AI-based Control	Fuzzy logic, ANN, RL	Self-learning, robust	Requires training and tuning
Multi-level Converter Control	Multi-level PWM	Inherent harmonic reduction	Complex design, cost

CASE STUDIES AND APPLICATIONS

1. Solar PV Systems

- Grid-tied PV inverters generate high-frequency switching harmonics.
- AI-assisted shunt APFs reduce THD from 12–15% to below 5%, ensuring compliance with IEEE 519.
- Multi-level inverter topologies further improve voltage waveform quality.

2. Wind Energy Systems

- DFIG-based turbines produce low-order harmonics due to rotor-side converters.
- Model predictive control and series APFs effectively mitigate harmonics while maintaining maximum power point tracking.

3. Microgrids and Hybrid Systems

- In microgrids with multiple RES and storage units, harmonic propagation is complex.
- Distributed smart sensors and AI-based controllers coordinate harmonics mitigation across sources and loads.

CHALLENGES AND RESEARCH GAPS

Despite advances, several challenges remain:

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

1. **Dynamic renewable generation** – Rapid fluctuations complicate harmonic prediction and control.
2. **Cost of smart sensors** – Widespread deployment increases system cost.
3. **Computational complexity** – AI and predictive algorithms require high-speed processors.
4. **Integration with grid codes** – Compliance with evolving standards requires adaptive strategies.
5. **Scalability in microgrids** – Coordinating multiple distributed converters is still a research challenge.

FUTURE DIRECTIONS

Promising research directions include:

- **Digital twin-based harmonic management** – Real-time simulation of converter behavior for proactive mitigation.
- **Edge computing in IoT sensors** – Reducing latency in harmonic control loops.
- **Hybrid AI methods** – Combining reinforcement learning, fuzzy logic, and predictive control for enhanced robustness.
- **Low-cost wideband sensors** – Affordable, accurate measurement across all harmonic orders.
- **Integration with energy management systems** – Harmonizing harmonic control with overall system optimization.

CONCLUSION

Converter-induced harmonics are a significant challenge in renewable energy systems, threatening power quality, equipment longevity, and grid stability. Traditional methods, though effective in some scenarios, lack adaptability in dynamic renewable environments. This paper reviewed **smart sensing and advanced control strategies** that leverage real-time monitoring, AI-based prediction, and adaptive filtering to mitigate harmonic distortion effectively. Integration of smart sensors with predictive and AI controllers offers high accuracy, adaptability, and compliance with grid standards. Future research should focus on scalable, cost-effective, and intelligent harmonic management to ensure seamless renewable energy integration into modern power systems.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved

REFERENCES

1. IEEE Standard 519-2014, *IEEE Recommended Practices and Requirements for Harmonic Control in Electric Power Systems*.
2. B. Singh, K. Al-Haddad, and A. Chandra, *Power Quality: Problems and Mitigation Techniques*, IEEE Press, 2020.
3. J. Rodriguez, S. Bernet, B. Wu, J. Pontt, and S. Kouro, "Multilevel voltage-source-converter topologies for industrial medium-voltage drives," *IEEE Trans. Ind. Electron.*, vol. 54, no. 6, pp. 2930–2945, 2007.
4. Jain, R. Gupta, and S. Mahajan, "AI-based harmonic mitigation in grid-tied photovoltaic systems," *Renew. Energy*, vol. 168, pp. 1150–1162, 2021.
5. M. Malinowski, K. Gopakumar, J. Rodriguez, and M. A. Perez, "A survey on cascaded multilevel inverters," *IEEE Trans. Ind. Electron.*, vol. 57, no. 7, pp. 2197–2206, 2010.
6. S. K. Singh, N. Verma, and R. Sharma, "Smart sensing of power quality in renewable microgrids," *Energy Reports*, vol. 7, pp. 245–258, 2021.
7. L. H. F. Oliveira, F. A. Farret, and M. Godoy Simoes, "Digital control techniques for harmonic reduction in inverter-based distributed generation systems," *IEEE Trans. Power Electron.*, vol. 22, no. 6, pp. 2235–2243, 2007.
8. P. Vas, *Artificial-Intelligence-Based Electrical Machines and Drives*, Oxford University Press, 2013.
9. R. Cardenas, J. Rodriguez, and M. Castilla, "Predictive control strategies for active power filters in renewable energy systems," *IEEE Trans. Ind. Appl.*, vol. 52, no. 3, pp. 2345–2354, 2016.
10. N. Kumar, S. Mahajan, and A. Joshi, "Adaptive harmonic mitigation in hybrid renewable microgrids using AI-based controllers," *Int. J. Electr. Power Energy Syst.*, vol. 132, pp. 1071–1083, 2022.

Page 1113-125 © MANTECH PUBLICATIONS 2020. All Rights Reserved